

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1130:192 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Honeywell Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models XLS757-1A-MT and XLS757-1A-MTW electronic horns. Models with the letter "M" in the suffix are master units. Master units provide synchronization when used with slave units (models without "M" in the suffix). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/audible ratings and UL label.

APPROVAL: Listed as electronic horns for use with separately listed compatible fire alarm control units. Suitable for outdoor use when installed with listed weatherproof back box.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLf: 7135-1388:213

07-27-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 14, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager